



Product Service

# CERTIFICATE

No. Z1A 16 01 12906 238

Holder of Certificate: **DÜPERTHAL SICHERHEITSTECHNIK GMBH & Co. KG**



**DÜPERTHAL**  
SICHERHEITSTECHNIK

Frankenstraße 3  
63791 Karlstein  
GERMANY

Factory(ies): 62099

Certification Mark:



Product: **Safety cabinets**  
Model(s): **CLASSIC line, 29-HHBBTu-xyz(ss)  
COMPACT line, 29-20BBTu-xyz(ss)**

Parameters: Key code Art.-No.

HH	height, stands for number:	13, 20
BB	width, stands for number:	06, 09, 12, 17
T	depth, stands for number:	6, 7
u	door technique, stands for number:	0, 1, 3, 5, 7, 9
x	colour, stands for number;	0, 4, 5, 6, 7
yz	interior fitting, stands for number:	00-99
ss	special sign, stands for:	B, L, R, U, A

Class of fire resistance: FWF 90  
The material number defined exact material and size of the single products. A full description of the specifications is provided in the test report.

Tested according to: DIN EN 14470-1:2004  
DIN EN 14727:2006  
EK5/AK4 09-10:2009  
TRGS 510:01-2013 Anlage 3  
AfPS GS 2014:01 PAK

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

Test report no.: 713056815  
Valid until: 2021-01-14

Date, 2016-01-19 (Edgar Harnisch)

Page 1 of 1

