



**PRODUCT NUMBER: 2091921**  
**ELECTROSOFT CLASS 2**

Handling of high voltage to 17 000 volts. To be used with leather protectors for mechanical protection.

**Honeywell**

## Overview

**Reference Number**

2091921

**Product Type**

Gloves

**Range**

Electrical Protection

**Line**

Latex

**Brand**

Honeywell

**Brand formerly known as**

ELECTROSOFT

**Industry**

- Energy or Electricity
- Maintenance
- Telecoms

**Product Use**

Handling of high voltage to 17 000 volts. To be used with leather protectors for mechanical protection.

## Features & Benefits

**Feature**

Beige natural latex insulating glove

Cut edge

Category RC

**Benefit**

COMFORT

Its ergonomic shape and lightly powdered interior make the glove easy to slip on and off.

RESISTANCE

Its natural latex base offers high dielectric characteristics.

Its thickness (2.3 mm) ensures good dexterity while offering protection up to 17,000 volts of use.

SAFETY

To be used with leather protectors for mechanical protection.

## Technical Description

### Description

CE CATEGORY : III Irreversible risks

In accordance with standards :

EN 60903-2003

CEI 903-2002

### CHARACTERISTICS :

Beige natural latex insulating glove

Category RC

### Product Technology

Dipped Gloves

### Glove/liner color

Beige

### Coating Color

Latex

### Length

36 cm

### Thickness

2.3 mm

### Harmlessness

In conformity with the European standards

### Dexterity

Class 2

### Sizes

8 to 11

## Packaging Label

### Tagging

CE HONEYWELL

2091921 XX

EN 60903-2003

CEI 903-2002

## Certifications

### EC Category PPE

3

### Quality Assurance

ISO 9001 / 2000

### EC Certificate Number

7008

### EC Attestation

EC Attestation

### EC Attestation Number

7008

## Additional Information

### User Information Sheet

On the polybag

## Maintenance

### Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

### Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

### Care Instructions

Inspection : Before each use, carry out a visual inspection and check the glove inflation.

Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity